

# Part # C865

**Primary .2 - .8**

**Secondary 7.0k - 13.0k**

## Physical Inspection

1. Check for corrosion on terminals
2. Check for cracks or carbon tracking

