

Part # C967

Primary .15 - .6

Secondary 6.5k - 12.0k

Physical Inspection

1. Check for corrosion on terminals
2. Check for cracks or carbon tracking

